

XARXA D'AIGUA REGENERADA DE LLORET DE MAR. ANY 2017.



**MAIG 2017**

Dia	QUALITAT FISICO-QUIMICA																											
	MES mg/L				Terb UNT				CE dS/m				Trans. %				pH				Redox mV				Oxigen mg/L			
	PL	XLL1	XLL2	XLL3	PL	XLL1	XLL2	XLL3	PL	XLL1	XLL2	XLL3	PL	XLL1	XLL2	XLL3	PL	XLL1	XLL2	XLL3	PL	XLL1	XLL2	XLL3	PL	XLL1	XLL2	XLL3
1																												
2																												
3	8.8				5.1			1.49				47				7.7				337				8.5				
4																												
5					5.5																							
6																												
7																												
8	4.6				4.0			1.52				54				7.7				279				8.2				
9																												
10					5.7																							
11																												
12																												
13																												
14																												
15	7.4				4.8			1.54				51				7.7				331				7.7				
16					5.0																							
17																												
18																												
19																												
20																												
21																												
22	11.0				4.9			1.45				47				7.6				234				7.8				
23																												
24		8.0	7.0		2.6	4.0	2.6		1.42	1.40			75	79		8.0	8.1		194	180			9.0	8.9				
25																												
26																												
27																												
28																												
29																												
30	6.6				4.0			1.48				47				7.7				243				6.9				
31																												

Totals	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Mitjana	7.7	8.0			4.6	4.0		1.50	1.42			49	75		7.7	8.0			285	194			7.8	9.0			
Mediana	7.4	8.0			4.9	4.0		1.49	1.42			47	75		7.7	8.0			279	194			7.8	9.0			
Percentil 10	5.4	8.0			3.7	4.0		1.47	1.42			47	75		7.6	8.0			238	194			7.2	9.0			
Percentil 90	10.1	8.0			5.5	4.0		1.53	1.42			53	75		7.7	8.0			335	194			8.4	9.0			
Màxim	11.0	8.0			5.7	4.0		1.54	1.42			54	75		7.7	8.0			337	194			8.5	9.0			
Mínim	4.6	8.0			2.6	4.0		1.45	1.42			47	75		7.6	8.0			234	194			6.9	9.0			
Nº casos	5	1			9	1		5	1			5	1		5	1			5	1			5	1			

Valor de ref. P90<20 P90<10 <3.0  
Els números en vermell indiquen "menor que"



XARXA D'AIGUA REGENERADA DE LLORET DE MAR. ANY 2017.



MAIG 2017																	
Dia	NUTRIENTS														Volum m3 Xarxa		
	NTK mg N/L				NH4-N mg N/L				NO3-N mg N/L				P Total mg N/L				
	PL	XLL1	XLL2	XLL3	PL	XLL1	XLL2	XLL3	PL	XLL1	XLL2	XLL3	PL	XLL1		XLL2	XLL3
1																	151
2																	0
3	47,0				45,0				0,3				4,4				138
4																	200
5																	83
6																	78
7																	63
8																	0
9																	312
10	49,0				46,0				0,2				4,2				0
11																	306
12																	112
13																	224
14																	174
15																	94
16																	642
17	50,0				48,0				0,2				4,4				728
18																	75
19																	101
20																	140
21																	68
22																	307
23																	299
24	44,0				40,0				0,2				4,4				439
25		37,0	34,7			36,0	33,8			0,6	0,8			2,2	2,2		400
26																	272
27																	379
28																	379
29																	379
30																	379
31	44,0				40,0				0,3				2,4				380
<b>Totals</b>	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	7.302
<b>Mitjana</b>	46,8	37,0			43,8	36,0			0,2	0,6			4,0	2,2			236
<b>Mediana</b>	47,0	37,0			45,0	36,0			0,2	0,6			4,4	2,2			
<b>Percentil 10</b>	44,0	37,0			40,0	36,0			0,2	0,6			3,1	2,2			
<b>Percentil 90</b>	49,6	37,0			47,2	36,0			0,3	0,6			4,4	2,2			
<b>Màxim</b>	50,0	37,0			48,0	36,0			0,3	0,6			4,4	2,2			
<b>Mínim</b>	44,0	37,0			40,0	36,0			0,2	0,6			2,4	2,2			
<b>Nº casos</b>	5	1			5	1			5	1			5	1			