

XARXA D'AIGUA REGENERADA DE LLORET DE MAR. ANY 2017.



OCTUBRE 2017

Dia	QUALITAT FISICO-QUIMICA																											
	MES mg/L				Terb UNT				CE dS/m				Trans. %				pH				Redox mV				Oxigen mg/L			
	PL	XLL1	XLL2	XLL3	PL	XLL1	XLL2	XLL3	PL	XLL1	XLL2	XLL3	PL	XLL1	XLL2	XLL3	PL	XLL1	XLL2	XLL3	PL	XLL1	XLL2	XLL3	PL	XLL1	XLL2	XLL3
1																												
2	7.2				6.1				1.19				41				7.5				309				8.1			
3																												
4					5.6																							
5																												
6																												
7																												
8																												
9	6.6				5.9				1.35				42				7.5				270				7.6			
10																												
11					6.1																							
12																												
13																												
14																												
15																												
16	8.0				6.7				1.40				50				7.6				283				8.1			
17																												
18		7.0	5.0	5.0	5.9	1.6	1.5	1.5	1.38	1.37	1.35		79	71	78		7.6	7.8	7.7		176	187	185		5.8	6.4	1.9	
19																												
20																												
21																												
22																												
23	4.6				3.3				1.33				56				7.5				327				8.4			
24																												
25																												
26					5.0																							
27																												
28																												
29																												
30																												
31	4.2				3.8				1.47				49				7.4				340				7.9			

Totals	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Mitjana	6.1	7.0	5.0	5.4	1.6	1.5	1.35	1.38	1.35	48	79	78	7.5	7.6	7.7	306	176	185	8.0	5.8	1.9						
Mediana	6.6	7.0	5.0	5.9	1.6	1.5	1.35	1.38	1.35	49	79	78	7.5	7.6	7.7	309	176	185	8.1	5.8	1.9						
Percentil 10	4.4	7.0	5.0	3.7	1.6	1.5	1.25	1.38	1.35	41	79	78	7.4	7.6	7.7	275	176	185	7.7	5.8	1.9						
Percentil 90	7.7	7.0	5.0	6.2	1.6	1.5	1.44	1.38	1.35	54	79	78	7.6	7.6	7.7	335	176	185	8.3	5.8	1.9						
Màxim	8.0	7.0	5.0	6.7	1.6	1.5	1.47	1.38	1.35	56	79	78	7.6	7.6	7.7	340	176	185	8.4	5.8	1.9						
Mínim	4.2	7.0	5.0	3.3	1.6	1.5	1.19	1.38	1.35	41	79	78	7.4	7.6	7.7	270	176	185	7.6	5.8	1.9						
Nº casos	5	1	1	9	1	1	5	1.00	1.00	5	1	1	5	1	1	5	1	1	5	1	1	1	5	1	1	1	

Valor de ref. P90<20 P90<10 <3.0
Els números en vermell indiquen "menor que"

XARXA D'AIGUA REGENERADA DE LLORET DE MAR. ANY 2017.



OCTUBRE 2017																	
Dia	NUTRIENTS															Volum m3 Xarxa	
	NTK mg N/L				NH4-N mg N/L				NO3-N mg N/L				P Total mg N/L				
	PL	XLL1	XLL2	XLL3	PL	XLL1	XLL2	XLL3	PL	XLL1	XLL2	XLL3	PL	XLL1	XLL2		XLL3
1																	218
2																	141
3																	173
4	24,0				22,0				0,3				1,7				166
5																	159
6																	163
7																	211
8																	209
9																	116
10																	117
11	35,0				34,0				0,2				1,8				323
12																	338
13																	326
14																	109
15																	65
16																	151
17																	141
18	36,0				35,0				0,3				4,3				117
19		28,0	27,3	24,5		23,7	23,0	20,5		0,6	1,2	0,7		3,4	3,1	2,8	221
20																	215
21																	102
22																	129
23																	118
24																	210
25	27,0				26,0				0,3				4,2				135
26																	58
27																	154
28																	94
29																	61
30																	160
31																	262
Totals	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	5.162
Mitjana	30,5	28,0		24,5	29,3	23,7		20,5	0,3	0,6		0,7	3,0	3,4		2,8	167
Mediana	31,0	28,0		24,5	30,0	23,7		20,5	0,3	0,6		0,7	3,0	3,4		2,8	
Percentil 10	24,9	28,0		24,5	23,2	23,7		20,5	0,2	0,6		0,7	1,7	3,4		2,8	
Percentil 90	35,7	28,0		24,5	34,7	23,7		20,5	0,3	0,6		0,7	4,3	3,4		2,8	
Màxim	36,0	28,0		24,5	35,0	23,7		20,5	0,3	0,6		0,7	4,3	3,4		2,8	
Mínim	24,0	28,0		24,5	22,0	23,7		20,5	0,2	0,6		0,7	1,7	3,4		2,8	
Nº casos	4	1		1	4	1		1	4	1		1	4	1		1	