

XARXA D'AIGUA REGENERADA DE LLORET DE MAR. ANY 2017.



**DESEMBRE 2017**

Dia	QUALITAT FISICO-QUIMICA																											
	MES mg/L				Terb UNT				CE dS/m				Trans. %				pH				Redox mV				Oxigen mg/L			
	PL	XLL1	XLL2	XLL3	PL	XLL1	XLL2	XLL3	PL	XLL1	XLL2	XLL3	PL	XLL1	XLL2	XLL3	PL	XLL1	XLL2	XLL3	PL	XLL1	XLL2	XLL3	PL	XLL1	XLL2	XLL3
1																												
2																												
3																												
4	2,8				2,5			1,30				59				7,3				333				6,4				
5					2,1																							
6																												
7																												
8																												
9																												
10																												
11	2,8				3,4			1,29				60				7,6				337				7,1				
12		5,0	5,0	7,0		1,2	0,7	1,1		1,29	1,28	1,28		92	95	95		8,0	8,2	8,1		197	199	199		9,2	8,9	7,0
13					3,1																							
14																												
15																												
16																												
17																												
18	2,8				2,0			1,34				61				7,4				341				7,3				
19					2,2																							
20																												
21																												
22																												
23																												
24																												
25																												
26																												
27	2,8				2,0			1,32				52				7,5				381				8,0				
28					2,6																							
29																												
30																												
31																												

Totals	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Mitjana	2,8	5,0	7,0	2,5	1,2	1,1	1,32	1,29	1,28	58	92	95	7,5	8,0	8,1	348	197	199	7,2	9,2	7,0						
Mediana	2,8	5,0	7,0	2,4	1,2	1,1	1,31	1,29	1,28	60	92	95	7,5	8,0	8,1	339	197	199	7,2	9,2	7,0						
Percentil 10	2,8	5,0	7,0	2,0	1,2	1,1	1,30	1,29	1,28	54	92	95	7,3	8,0	8,1	334	197	199	6,6	9,2	7,0						
Percentil 90	2,8	5,0	7,0	3,2	1,2	1,1	1,34	1,29	1,28	61	92	95	7,6	8,0	8,1	369	197	199	7,8	9,2	7,0						
Màxim	2,8	5,0	7,0	3,4	1,2	1,1	1,34	1,29	1,28	61	92	95	7,6	8,0	8,1	381	197	199	8,0	9,2	7,0						
Mínim	2,8	5,0	7,0	2,0	1,2	1,1	1,29	1,29	1,28	52	92	95	7,3	8,0	8,1	333	197	199	6,4	9,2	7,0						
Nº casos	4	1,0	1	8	1	1	4	1,00	1,00	4	1	1	4	1	1	4	1	1	4	1	1	4	1	1	4	1	

Valor de ref. P90<20 P90<10 <3,0  
Els números en vermell indiquen "menor que"



XARXA D'AIGUA REGENERADA DE LLORET DE MAR. ANY 2017.



DESEMBRE 2017																	
Dia	NUTRIENTS														Volum		
	NTK mg N/L				NH4-N mg N/L				NO3-N mg N/L				P Total mg N/L			m3	Xarxa
	PL	XLL1	XLL2	XLL3	PL	XLL1	XLL2	XLL3	PL	XLL1	XLL2	XLL3	PL	XLL1	XLL2	XLL3	
1																	148
2																	104
3																	72
4	24,0				18,0				0,4					3,7			147
5																	122
6																	121
7																	124
8																	212
9																	160
10																	149
11																	107
12		4,0	4,0	4,5		6,8	5,5	4,6		0,6	3,3	3,3		2,4	0,8	0,8	95
13	12,0				11,0				0,2					4,4			115
14																	213
15																	179
16																	200
17																	100
18																	135
19	13,0				12,0				0,2					1,1			50
20																	102
21																	95
22																	129
23																	50
24																	79
25																	85
26	23,0				19,0				0,3					4,3			120
27																	92
28																	171
29																	108
30																	90
31																	74
<b>Totals</b>	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	3.748
<b>Mitjana</b>	18,0	4,0		4,5	15,0	6,8		4,6	0,3	0,6		3,3	3,4	2,4		0,8	121
<b>Mediana</b>	18,0	4,0		4,5	15,0	6,8		4,6	0,3	0,6		3,3	4,0	2,4		0,8	
<b>Percentil 10</b>	12,3	4,0		4,5	11,3	6,8		4,6	0,2	0,6		3,3	1,9	2,4		0,8	
<b>Percentil 90</b>	23,7	4,0		4,5	18,7	6,8		4,6	0,4	0,6		3,3	4,4	2,4		0,8	
<b>Màxim</b>	24,0	4,0		4,5	19,0	6,8		4,6	0,4	0,6		3,3	4,4	2,4		0,8	
<b>Mínim</b>	12,0	4,0		4,5	11,0	6,8		4,6	0,2	0,6		3,3	1,1	2,4		0,8	
<b>Nº casos</b>	4	1		1	4	1		1	4	1		1	4	1		1	