

XARXA D'AIGUA REGENERADA DE TOSSA DE MAR. ANY 2017.

**GENER 2017**

Dia	QUALITAT FÍSICO-QUÍMICA																				
	MES			Terb			CE			Trans.			pH			Redox			Oxigen		
	mg/L			UNT			dS/m			%			mV			mg/L					
	Dipòsit	XT5	XT8	Dipòsit	XT5	XT8	Dipòsit	XT5	XT8	Dipòsit	XT5	XT8	Dipòsit	XT5	XT8	Dipòsit	XT5	XT8	Dipòsit	XT5	XT8
1																					
2	5,0			4,6			1,44			59			7,8			427			9,8		
3																					
4				4,5																	
5																					
6																					
7																					
8																					
9	7,2			4,9			1,36			57			7,9			374			9,9		
10		8,0	5,0	5,1	2,0	2,0	1,43	1,39		80	76		7,9	7,8		164	189		8,1	7,9	
11																					
12																					
13																					
14																					
15																					
16	4,6			4,8			1,25			55			7,9			445			9,5		
17																					
18				5,9																	
19																					
20																					
21																					
22																					
23	6,4			5,9			1,30			40			8,0			446			10,2		
24																					
25				4,0																	
26																					
27																					
28																					
29																					
30	6,0			5,5			1,37			49			8,0			421			10,0		
31																					

Totals	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Mitjana	5,8	8,0	5,0	5,0	2,0	2,0	1,34	1,43	1,39	52	80	76	7,92	7,87	7,80	423	164	189	9,9	8,1	7,9
Mediana	6,0	8,0	5,0	4,9	2,0	2,0	1,36	1,43	1,39	55	80	76	7,90	7,87	7,80	427	164	189	9,9	8,1	7,9
Percentil 10	4,8	8,0	5,0	4,4	2,0	2,0	1,27	1,43	1,39	44	80	76	7,84	7,87	7,80	393	164	189	9,6	8,1	7,9
Percentil 90	6,9	8,0	5,0	5,9	2,0	2,0	1,41	1,43	1,39	58	80	76	8,00	7,87	7,80	446	164	189	10,1	8,1	7,9
Màxim	7,2	8,0	5,0	5,9	2,0	2,0	1,44	1,43	1,39	59	80	76	8,00	7,87	7,80	446	164	189	10,2	8,1	7,9
Mínim	4,6	8,0	5,0	4,0	2,0	2,0	1,25	1,43	1,39	40	80	76	7,80	7,87	7,80	374	164	189	9,5	8,1	7,9
Nº casos	5	1,0	1	9	1	1	5	1,00	1,00	5	1	1	5,0	1,0	1,0	5	1	1	5	1	1

Valor de ref. P90<20 P90<10 <3,0  
Els números en vermell indiquen "menor que"



XARXA D'AIGUA REGENERADA DE TOSSA DE MAR. ANY 2017.

GENER 2017													
Dia	NUTRIENTS			NUTRIENTS			NUTRIENTS			NUTRIENTS			Volum
	NTK			NH4-N			NO3-N			P Total			m3
	mg N/L			mg N/L			mg N/L			mg N/L			Xarxa
	Dipòsit	XT5	XT8	Dipòsit	XT5	XT8	Dipòsit	XT5	XT8	Dipòsit	XT5	XT8	
1													45
2													73
3													96
4	25,0			22,0			0,4			2,5			86
5													98
6													98
7													98
8													99
9													47
10													82
11	8,4	10	9	6,7	8	6	0,1	0,8	1,0	3,5	3,9	3,4	79
12													82
13													89
14													88
15													88
16													20
17													69
18	11,0			10,0			0,4			1,6			55
19													48
20													19
21													19
22													18
23													26
24													16
25	5,0			3,4			0,4			0,7			38
26													47
27													27
28													27
29													26
30													17
31													16
<b>Totals</b>	-	-	-	-	-	-	-	-	-	-	-	-	1.736
<b>Mitjana</b>	12,4	10,1	9,2	10,5	7,6	5,7	0,3	0,8	1,0	2,1	3,9	3,4	56
<b>Mediana</b>	9,7	10,1	9,2	8,4	7,6	5,7	0,4	0,8	1,0	2,1	3,9	3,4	
<b>Percentil 10</b>	6,0	10,1	9,2	4,4	7,6	5,7	0,2	0,8	1,0	1,0	3,9	3,4	
<b>Percentil 90</b>	20,8	10,1	9,2	18,4	7,6	5,7	0,4	0,8	1,0	3,2	3,9	3,4	
<b>Màxim</b>	25,0	10,1	9,2	22,0	7,6	5,7	0,4	0,8	1,0	3,5	3,9	3,4	
<b>Mínim</b>	5,0	10,1	9,2	3,4	7,6	5,7	0,1	0,8	1,0	0,7	3,9	3,4	
<b>Nº casos</b>	4	1	1	4	1	1	4	1	1	4	1	1	